

Certificate of Compliance

This is to certify that

EDGE ANALYTICAL, Inc.,

An Accredited Drinking Water Laboratory,


Certification number 046, has completed the analysis of

DRINKMORE WATER/DRINKMORE DELIVERY INC

“Purified Water”

on October 24, 2022, according to the IBWA “Appendix A” testing requirements for bottled drinking water. All parameters were found to be in compliance with FDA’s and IBWA’s published Standard of Quality limits for bottled drinking water.

EDGE
ANALYTICAL



Director of Laboratories, Vice President

22-30234



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd. Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

October 24, 2022

Page 1 of 1

Mr. Bob Perini
Drinkmore Water/Drinkmore Delivery Inc
7595 Rickenbacker Drive
Gaithersburg, MD 20879

RE: 22-30234 - 50 State Product - Purified Water

Dear Mr. Bob Perini,

Your project: 50 State Product - Purified Water, was received on Thursday September 01, 2022.

All samples were analyzed within the accepted holding times and were appropriately preserved and analyzed according to approved analytical protocols, unless noted in the data or QC reports. The quality control data was within laboratory acceptance limits, unless specified in the data or QC reports.

If you have questions phone us at 800 755-9295.

Respectfully

A handwritten signature in blue ink that reads "Lawrence J Henderson". The signature is fluid and cursive.

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Enclosures: Data Report
QC Reports
Chain of Custody



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
 Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: Drinkmore Water/Drinkmore Delivery Inc
 7595 Rickenbacker Drive
 Gaithersburg, MD 20879

Reference Number: **22-30234**

Authorized by:

Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Project: 50 State Product - Purified Water
 Field ID: 50 State Product
 Sample Description: Purified Water
 Sampled By:
 Sample Date: 09/14/2022

Lab Number: **58714**

Report Date: 10/24/2022

Approved By: anp,bj,crc,ljh,mcs,pdm,tjb

Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
57-12-5	CYANIDE	ND	0.2	0.005	mg/L	OIA-1677-DW	a	
7440-36-0	ANTIMONY	ND	0.006	0.001	mg/L	200.8	a	
7440-38-2	ARSENIC	ND	0.010	0.001	mg/L	200.8	a	
7440-39-3	BARIUM	ND	1.0	0.001	mg/L	200.8	a	
7440-41-7	BERYLLIUM	ND	0.004	0.001	mg/L	200.8	a	
7440-43-9	CADMIUM	ND	0.005	0.001	mg/L	200.8	a	
7440-47-3	CHROMIUM	ND	0.05	0.001	mg/L	200.8	a	
16984-48-8	FLUORIDE	ND	2	0.10	mg/L	300.0	a	
7439-92-1	LEAD	ND	0.005	0.001	mg/L	200.8	a	
7439-97-6	MERCURY	ND	0.001	0.0002	mg/L	200.8	a	
7440-02-0	NICKEL	ND	0.1	0.001	mg/L	200.8	a	
14797-55-8	NITRATE-N	ND	10	0.10	mg/L	300.0	a	
14797-65-0	NITRITE-N	ND	1.0	0.10	mg/L	300.0	a	
E-10128	TOTAL NITRATE+NITRITE as N	ND	10	0.10	mg/L	300.0	a	
7782-49-2	SELENIUM	ND	0.010	0.005	mg/L	200.8	a	
7440-28-0	THALLIUM	ND	0.002	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

If you have any questions concerning this report contact us at the above phone number.

BOTTLED WATER STANDARD OF QUALITY REPORT

Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7429-90-5	ALUMINUM	ND	0.2	0.010	mg/L	200.7	a	
16887-00-6	CHLORIDE	0.29	250	0.1	mg/L	300.0	a	
7440-50-8	COPPER	ND	1.0	0.005	mg/L	200.8	a	
7439-89-6	IRON	ND	0.3	0.050	mg/L	200.7	a	
7439-96-5	MANGANESE	ND	0.05	0.001	mg/L	200.8	a	
7440-22-4	SILVER	ND	0.025	0.001	mg/L	200.8	a	
14808-79-8	SULFATE	ND	250	10	mg/L	300.0	a	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	ND	500	10	mg/L	SM2540 C	a	
7440-66-6	ZINC	ND	5.00	0.005	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
75-35-4	1,1 - DICHLOROETHYLENE	ND	2	0.5	ug/L	524.2	a	
71-55-6	1,1,1 - TRICHLOROETHANE	ND	30	0.5	ug/L	524.2	a	
79-00-5	1,1,2 - TRICHLOROETHANE	ND	5	0.5	ug/L	524.2	a	
107-06-2	1,2 - DICHLOROETHANE	ND	2	0.5	ug/L	524.2	a	
78-87-5	1,2 - DICHLOROPROPANE	ND	5	0.5	ug/L	524.2	a	
120-82-1	1,2,4 - TRICHLOROBENZENE	ND	9	0.5	ug/L	524.2	a	
71-43-2	BENZENE	ND	1	0.5	ug/L	524.2	a	
56-23-5	CARBON TETRACHLORIDE	ND	2	0.5	ug/L	524.2	a	
156-59-2	CIS - 1,2 - DICHLOROETHYLENE	ND	70	0.5	ug/L	524.2	a	
156-60-5	TRANS - 1,2 - DICHLOROETHYLENE	ND	100	0.5	ug/L	524.2	a	
100-41-4	ETHYLBENZENE	ND	700	0.5	ug/L	524.2	a	
75-09-2	DICHLOROMETHANE	ND	3	0.5	ug/L	524.2	a	
108-90-7	MONOCHLOROENZENE	ND	50	0.5	ug/L	524.2	a	
95-50-1	O - DICHLOROENZENE	ND	600	0.5	ug/L	524.2	a	
106-46-7	P - DICHLOROENZENE	ND	75	0.5	ug/L	524.2	a	
100-42-5	STYRENE	ND	100	0.5	ug/L	524.2	a	
127-18-4	TETRACHLOROETHYLENE	ND	1	0.5	ug/L	524.2	a	
108-88-3	TOLUENE	ND	1000	0.5	ug/L	524.2	a	
79-01-6	TRICHLOROETHYLENE	ND	1	0.5	ug/L	524.2	a	
75-01-4	VINYL CHLORIDE	ND	2	0.5	ug/L	524.2	a	
1330-20-7	XYLENES (TOTAL)	ND	1000	0.5	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Synthetic Organic Chemicals (SOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
94-75-7	2,4 - D	ND	70	0.1	ug/L	515.4	a	
93-72-1	2,4,5 - TP (SILVEX)	ND	10	0.2	ug/L	515.4	a	
16655-82-6	3-HYDROXYCARBOFURAN	ND		1.0	ug/L	531.2	a	
15972-60-8	ALACHLOR	ND	2	0.2	ug/L	525.2	a	
116-06-3	ALDICARB	ND		1.0	ug/L	531.2	a	
1646-88-4	ALDICARB SULFONE	ND		1.6	ug/L	531.2	a	
1646-87-3	ALDICARB SULFOXIDE	ND		1.0	ug/L	531.2	a	
309-00-2	ALDRIN	ND		0.1	ug/L	525.2	a	
1912-24-9	ATRAZINE	ND	3	0.1	ug/L	525.2	a	
50-32-8	BENZO(A)PYRENE	ND	0.2	0.02	ug/L	525.2	a	
23184-66-9	BUTACHLOR	ND		0.1	ug/L	525.2	a	
63-25-2	CARBARYL	ND		1.0	ug/L	531.2	a	
1563-66-2	CARBOFURAN	ND	40	0.9	ug/L	531.2	a	
57-74-9	CHLORDANE	ND	0.5	0.2	ug/L	508.1	a	
75-99-0	DALAPON	ND	200	1	ug/L	515.4	a	
117-81-7	DI(2-ETHYLHEXYL)-PHTHALATE	ND	6	0.6	ug/L	525.2	a	
103-23-1	DI(2-ETHYLHEXYL)-ADIPATE	ND	400	0.6	ug/L	525.2	a	
96-12-8	1,2-DIBROMO-3-CHLOROPROPANE (DBCP)	ND	0.2	0.02	ug/L	504.1	a	
1918-00-9	DICAMBA	ND		0.2	ug/L	515.4	a	
60-57-1	DIELDRIN	ND		0.1	ug/L	525.2	a	
88-85-7	DINOSEB	ND	7	0.2	ug/L	515.4	a	
1746-01-6	DIOXIN (2,3,7,8-TETRACHLORODIBENZO-P-DIOXIN)	ND	30	5	pg/L	1613		Analyzed by PACE_MN
85-00-7	DIQUAT	ND	20	0.4	ug/L	549.2	a	
145-73-3	ENDOTHALL	ND	100	9	ug/L	548.1	a	
72-20-8	ENDRIN	ND	0.2	0.01	ug/L	525.2	a	
106-93-4	1,2 - DIBROMOETHANE (EDB)	ND	0.05	0.01	ug/L	504.1	a	
96-18-4	1,2,3 - TRICHLOROPROPANE	ND	0.03	0.02	ug/L	504.1	a	
1071-83-6	GLYPHOSATE	ND	700	6	ug/L	547	a	
76-44-8	HEPTACHLOR	ND	0.4	0.04	ug/L	525.2	a	
1024-57-3	HEPTACHLOR EPOXIDE "B"	ND	0.2	0.02	ug/L	525.2	a	
118-74-1	HEXACHLOROBENZENE	ND	1	0.1	ug/L	525.2	a	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	50	0.1	ug/L	525.2	a	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.2	0.02	ug/L	525.2	a	
16752-77-5	METHOMYL	ND		1.0	ug/L	531.2	a	
72-43-5	METHOXYCHLOR	ND	40	0.1	ug/L	525.2	a	
51218-45-2	METOLACHLOR	ND		0.1	ug/L	525.2	a	
21087-64-9	METRIBUZIN	ND		0.1	ug/L	525.2	a	
23135-22-0	OXAMYL (VYDATE)	ND	200	2	ug/L	531.2	a	
87-86-5	PENTACHLOROPHENOL	ND	1	0.04	ug/L	515.4	a	
1918-02-1	PICLORAM	ND	500	0.1	ug/L	515.4	a	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCBs)	ND	0.5	0.5	ug/L	508.1	a	
1918-16-7	PROPACHLOR	ND		0.1	ug/L	525.2	a	
122-34-9	SIMAZINE	ND	4	0.07	ug/L	525.2	a	
8001-35-2	TOXAPHENE	ND	3	1	ug/L	508.1	a	
E-10253	TOTAL PHENOLIC COMPOUNDS	ND	0.001	0.001	mg/L	420.4		Analyzed by NSF

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit.

BOTTLED WATER STANDARD OF QUALITY REPORT

Perfluorinated Compounds

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
763051-92-9	11-CHLOROEICOSAFLUORO-3-OXAUNDECANE-1-SULFONATE	ND		3.61	ng/L	537.1		Analyzed by Pace - FL
13252-13-6	2,3,3,3-TETRAFLUORO-2-(1,1,2,2,3,3,3-EPTAFLUOROPRO	ND		1.81	ng/L	537.1		
919005-14-4	4,8-DIOXA-3H-PERFLUORONONANOIC ACID (DONA, ADONA)	ND		3.61	ng/L	537.1		
756426-58-1	9-CHLOROHEXADECAFLUORO-3-OXANONANE-1-SULFONIC ACID	ND		1.81	ng/L	537.1		
2991-50-6	N-ETHYLPERFLUORO-1-OCTANESULFONAMIDOACETIC ACID (N	ND		3.61	ng/L	537.1		
2355-31-9	N-METHYLPERFLUORO-1-OCTANESULFONAMIDOACETIC ACID (ND		3.61	ng/L	537.1		
375-73-5	PERFLUOROBUTANESULFONIC ACID (PFBS)	ND		1.81	ng/L	537.1		
335-76-2	PERFLUORODECANOIC ACID (PFDA)	ND		1.81	ng/L	537.1		
307-55-1	PERFLUORODODECANOIC ACID (PFDOA)	ND		1.81	ng/L	537.1		
375-85-9	PERFLUOROHEPTANOIC ACID (PFHPA)	ND		1.81	ng/L	537.1		
355-46-4	PERFLUOROHEXANESULFONIC ACID (PFHXS)	ND		1.64	ng/L	537.1		
307-24-4	PERFLUOROHEXANOIC ACID (PFHXA)	ND		1.81	ng/L	537.1		
375-95-1	PERFLUORONONANOIC ACID (PFNA)	ND		1.81	ng/L	537.1		
1763-23-1	PERFLUOROCTANESULFONIC ACID (PFOS)	ND		3.61	ng/L	537.1		
335-67-1	PERFLUOROCTANOIC ACID (PFOA)	ND		1.81	ng/L	537.1		
376-06-7	PERFLUOROTETRADECANOIC ACID (PFTEDA)	ND		1.81	ng/L	537.1		
72629-94-8	PERFLUOROTRIDECANOIC ACID (PFTRDA)	ND		1.81	ng/L	537.1		
2058-94-8	PERFLUOROUNDECANOIC ACID (PFUnA)	ND		1.81	ng/L	537.1		

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit.

BOTTLED WATER STANDARD OF QUALITY REPORT

Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
1332-21-4	ASBESTOS	ND	7	0.098	MFL>10um	100.2		Analyzed by EMSL
E-10139	HYDROGEN ION (pH)	6.41			pH Units	150.1	a	Temp (C) : 20.8
NA	TASTE	ND		1	FTN	SM2160 B	a	
NA	MBAS (Surfactants)	ND		0.2	mg/L	SM5540 C		Analyzed By NSF
E-11712	COLOR	ND	15	5	COLOR UNIT	SM2120 B	a	pH6
E-11734	ODOR	ND	3	1	TON	SM2150	a	Temperature: 40.4
E-10617	TURBIDITY	ND	1	0.10	NTU	180.1	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit.

BOTTLED WATER STANDARD OF QUALITY REPORT

Disinfectants/DBP

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
15541-45-4	BROMATE	ND	0.010	0.001	mg/L	300.1	a	
10049-04-4	CHLORINE DIOXIDE	ND		0.10	mg/L	SM4500-CIO2 D	a	
7758-19-2	CHLORITE	ND	1.00	0.010	mg/L	300.1	a	
	CHLORAMINES TOTAL	ND	4.0	0.05	mg/L	SM4500-CI G	a	
7782-50-5	FREE CHLORINE RESIDUAL	ND	0.1	0.05	mg/L	SM4500-CI G	a	
NA	HAA(5)	ND	60	2	ug/L	552.3	a	Dup: ND
79-43-6	DICHLOROACETIC ACID	ND		1	ug/L	552.3	a	
76-03-9	TRICHLOROACETIC ACID	ND		1	ug/L	552.3	a	
631-64-1	DIBROMOACETIC ACID	ND		1	ug/L	552.3	a	
79-11-8	MONOCHLOROACETIC ACID	ND		2	ug/L	552.3	a	
79-08-3	MONOBROMOACETIC ACID	ND		1	ug/L	552.3	a	
E-14471	TOTAL TRIHALOMETHANE	7.2	10	0.5	ug/L	524.2	a	
75-27-4	BROMODICHLOROMETHANE	ND		0.5	ug/L	524.2	a	
124-48-1	CHLORODIBROMOMETHANE	ND		0.5	ug/L	524.2	a	
67-66-3	CHLOROFORM	7.2		0.5	ug/L	524.2	a	
75-25-2	BROMOFORM	ND		0.5	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
12587-46-1	GROSS ALPHA	ND	15	0	pCi/L	900.0		Analyzed by Pace
12587-47-2	GROSS BETA	ND	50	0	pCi/L	900.0		
13982-63-3	RADIUM 226	0.331			pCi/L	903.1		
15262-20-1	RADIUM 228	ND	5	5	pCi/L	904.0		
7440-61-1	URANIUM	ND	0.030	0.001	mg/L	200.8	a	
14859-67-7	RADON	ND		12.0	pCi/L	SM7500-Rn B		Analyzed by EEA IN

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Additional Volatile Organic Chemicals (New York)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
542-75-6	1,3-DICHLOROPROPYLENE, TOTAL	ND		0.5	ug/L	524.2	a	
75-34-3	1,1 - DICHLOROETHANE	ND		0.5	ug/L	524.2	a	
563-58-6	1,1 - DICHLOROPROPENE	ND		0.5	ug/L	524.2	a	
630-20-6	1,1,1,2 - TETRACHLOROETHANE	ND		0.5	ug/L	524.2	a	
79-34-5	1,1,2,2 - TETRACHLOROETHANE	ND		0.5	ug/L	524.2	a	
87-61-6	1,2,3 - TRICHLOROBENZENE	ND		0.5	ug/L	524.2	a	
96-18-4	1,2,3 - TRICHLOROPROPANE	ND		0.5	ug/L	524.2	a	
95-63-6	1,2,4 - TRIMETHYLBENZENE	ND		0.5	ug/L	524.2	a	
142-28-9	1,3 - DICHLOROPROPANE	ND		0.5	ug/L	524.2	a	
108-67-8	1,3,5 - TRIMETHYLBENZENE	ND		0.5	ug/L	524.2	a	
594-20-7	2,2 - DICHLOROPROPANE	ND		0.5	ug/L	524.2	a	
108-86-1	BROMOBENZENE	ND		0.5	ug/L	524.2	a	
74-97-5	BROMOCHLOROMETHANE	ND		0.5	ug/L	524.2	a	
74-83-9	BROMOMETHANE	ND		0.5	ug/L	524.2	a	
75-00-3	CHLOROETHANE	ND		0.5	ug/L	524.2	a	
74-87-3	CHLOROMETHANE	ND		0.5	ug/L	524.2	a	
10061-01-5	CIS - 1,3 - DICHLOROPROPENE	ND		0.5	ug/L	524.2	a	
74-95-3	DIBROMOMETHANE	ND		0.5	ug/L	524.2	a	
75-71-8	DICHLORODIFLUOROMETHANE	ND		0.5	ug/L	524.2	a	
87-68-3	HEXACHLOROBUTADIENE	ND		0.5	ug/L	524.2	a	
98-82-8	ISOPROPYLBENZENE	ND		0.5	ug/L	524.2	a	
541-73-1	M - DICHLOROBENZENE	ND		0.5	ug/L	524.2	a	
179601-23-1	M/P - XYLENE	ND		0.5	ug/L	524.2	a	
1634-04-4	METHYL TERT-BUTYL ETHER	ND		0.5	ug/L	524.2	a	
104-51-8	N - BUTYLBENZENE	ND		0.5	ug/L	524.2	a	
103-65-1	N - PROPYLBENZENE	ND		0.5	ug/L	524.2	a	
91-20-3	NAPHTHALENE	ND	14	0.5	ug/L	524.2	a	
95-49-8	O - CHLOROTOLUENE	ND		0.5	ug/L	524.2	a	
106-43-4	P - CHLOROTOLUENE	ND		0.5	ug/L	524.2	a	
95-47-6	O - XYLENE	ND		0.5	ug/L	524.2	a	
99-87-6	P - ISOPROPYLTOLUENE	ND		0.5	ug/L	524.2	a	
135-98-8	SEC - BUTYLBENZENE	ND		0.5	ug/L	524.2	a	
98-06-6	TERT - BUTYLBENZENE	ND		0.5	ug/L	524.2	a	
10061-02-6	TRANS- 1,3 - DICHLOROPROPENE	ND		0.5	ug/L	524.2	a	
75-69-4	TRICHLOROFLUOROMETHANE	ND		0.5	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Additional Inorganic Chemicals (New York)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
E-11778	HARDNESS	ND		10	mg CaCO3/L	200.7	a	
E-14506	ALKALINITY	2.8		1	mg CaCO3/L	SM2320 B	a	
NA	CORROSIVITY	-6.37			SI	SM203	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit .

BOTTLED WATER STANDARD OF QUALITY REPORT

Inorganic Chemicals (Massachusetts)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
1497-73-0	PERCHLORATE	ND	2	0.05	ug/L	331.0		Analyzed by Eurofins Eaton - Monrovia

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit .




Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Certificate Of Analysis

Client Name: Drinkmore Water/Drinkmore Delivery Inc
 7595 Rickenbacker Drive
 Gaithersburg, MD 20879

Reference Number: **22-30234**
 Project: 50 State Product - Purified W
 Report Date: 10/24/22
 Date Received: 9/1/22
 Approved By: bj,crc,ljh
 Authorized by:


 Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Sample Description: 50 State Product - Purified Water
 Lab Number: 58714

Sample Date: 9/14/22
 Collected By:

Parameter	RESULT	Method	Analyzed	Analyst	Batch	Comment
HYDROGEN ION (pH)	PASS	USP Mon. XXIII	9/16/22	CRC	USP_220916	Temp (C) : 20.8
OXIDIZIBLE SUBSTANCES	PASS	USP Mon. XXIII	9/16/22	CRC	USP_220916	
AMMONIA-N	PASS	USP Mon. XXIII	9/16/22	CRC	USP_220916	
HEAVY METALS	PASS	USP Mon. XXIII	9/16/22	CRC	USP_220916	
CARBON DIOXIDE	PASS	USP Mon. XXIII	9/16/22	CRC	USP_220916	
CALCIUM	PASS	USP Mon. XXIII	9/16/22	CRC	USP_220916	
SULFATE	PASS	USP Mon. XXIII	9/16/22	CRC	USP_220916	
CHLORIDE	PASS	USP Mon. XXIII	9/16/22	CRC	USP_220916	
TOTAL COLIFORM	ABSENT	SM9223 B/Colilert-1	9/15/22	BJ	M_220914BUR	
E. COLI	NEG	SM9223 B/Colilert-1	9/15/22	BJ	M_220914BUR	
TOTAL SOLIDS-WATER	PASS	SM2540 B	9/16/22	MSO	TS.W_220916	

Notes:

ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.
 PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.

If you have any questions concerning this report contact Lawrence Henderson at the above phone number.



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4945
Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Data Report

Client Name: Drinkmore Water/Drinkmore Delivery Inc
 7595 Rickenbacker Drive
 Gaithersburg, MD 20879

Reference Number: **22-30234**
 Project: 50 State Product - Purified Water

Report Date: 10/24/22

Date Received: 9/1/22

Approved by: anp,crc,tjb

Authorized by:

Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

Sample Description: 50 State Product Purified Water								Matrix BP	Sample Date: 9/14/22 11:09 am			
Lab Number: 58714		Sample Comment:						Collected By:				
CAS ID#	Parameter	Result	PQL	MDL	Units	DF	Method	Lab	Analyzed	Analyst	Batch	Comment
7440-70-2	CALCIUM	ND	0.5	0.03	mg/L	1.0	200.7	a	9/22/22	BJ	200.7_220922A	
7439-95-4	MAGNESIUM	ND	0.5	0.04	mg/L	1.0	200.7	a	9/22/22	BJ	200.7_220922A	
7440-23-5	SODIUM	1.2	0.5	0.05	mg/L	1.0	200.7	a	9/22/22	BJ	200.7_220922A	
7440-09-7	POTASSIUM	ND	1.0	0.02	mg/L	1.0	200.7	a	9/22/22	BJ	200.7_220922A	
24959-67-9	BROMIDE	ND	0.005	0.00019	mg/L	1.0	300.1	a	9/21/22	BJ	300.1_220921A	
E-10184	ELECTRICAL CONDUCTIVITY	ND	10		uS/cm	1.0	SM2510 B	a	9/19/22	JWN	EC_220919R	
	TOTAL COLIFORM For Taste Test	ABSENT	P/A		per 100mL	1.0	SM9223 B/Colliert-18	a	9/15/22	BJ	M_220914BUR	

Notes:

ND = Not detected above the listed practical quantitation limit (PQL) or not above the Method Detection Limit (MDL), if requested.
 PQL = Practical Quantitation Limit is the lowest level that can be achieved within specified limits of precision and accuracy during routine laboratory operating conditions.
 D.F. - Dilution Factor

If you have any questions concerning this report contact us at the above phone number.